

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 379/PW/PHD/EE-PA/2024

Dated: 11/07/2024


It is certified that an inspection team headed by Thiru. R. Gobalakichenane, Junior Engineer, Water Supply(P) Sub-Division, PHD, PWD, Puducherry, inspected The Scholar School, Korkadu, Villianur Puducherry on 10/07/2024 and found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T. Govt.

The above valid for a period of 1 year.

Signature with Seal :

Name :

Designation :


: T. UMABATHY, B.E., M.I.E.,
EXECUTIVE ENGINEER
PUBLIC HEALTH DIVISION
PUBLIC WORKS DEPARTMENT
PUDUCHERRY.

To

The Chairman,
The Scholar School,
Korkadu, Villianur
Puducherry.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2023/W-1848

Date: 30.12.2023

TEST REPORT- CHEMICAL

Customer Name & Address : The Chairman,
The Scholar School, Korkadu, Puducherry.
Customer Reference : Letter dt:28.12.2023

Page 1 of 1


SAMPLE DETAILS

Sample Code : 2024/W-1848	Information provided by the Customer Sampled on : 28.12.2023 Sample Description : Drinking Water Sample Source : -- Identification by Customer : Sample - 1 Sampling Location : School Campus, Korkadu, Puducherry.
Product Category : Water	
Sample Name : Drinking Water	
Sample Condition : Fit for analysis	
Sampled by : Customer	
Sample Received on : 28.12.2023	
Test Started on : 28.12.2023	
Test Completed on : 30.12.2023	

TEST RESULTS

CHEMICAL REPORT					
Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 23rd Edition, 2017, 4500-H ⁺ B	--	7.11	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 23rd Edition, 2017, 2510 B	µs/cm	1179	---	---
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/ dt.23.9.16	mg/L	731	500 Max	2000 Max
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 23rd Edition, 2017, 2320 B	mg/L	391	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 23rd Edition, 2017, 2340 C	mg/L	341	200 Max	600 Max
Iron as Fe	APHA, 23rd Edition, 2017, 3500 Fe B	mg/L	<0.10	1.0 Max	No Relaxation
Chloride as Cl	APHA, 23rd Edition, 2017, 4500-Cl B	mg/L	125	250 Max	1000 Max
Sulphate as SO ₄	APHA, 23rd Edition, 2017, 4500-SO ₄ E	mg/L	95.5	200 Max	400 Max
Nitrate as NO ₃	APHA, 23rd Edition, 2017, 4500-NO ₃ B	mg/L	<1.00	45 Max	No Relaxation
Fluoride as F	APHA, 23rd Edition, 2017, 4500-F D	mg/L	0.33	1.0 Max	1.5 Max

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERY

Copy submitted to:
The Executive Engineer,
PHD., P.W.D., Puducherry.

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.



GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY

Report No: TR/WTL/PHD/PDY/2023/B-0582

Date:30.12.2023

TEST REPORT

Page 1 of 1

Customer Name & Address : The Chairman,
The Scholar School, Korkadu, Puducherry.
Customer Reference : Letter dt.28.12.2023

SAMPLE DETAILS


Sample Code	: 2024/B-0582	Sampled by	Customer
Sample Name	: Water	Sampled on	28.12.2023
Sample Description	: Drinking Water		
Temperature	: --	Sampling Location	School Campus, Korkadu, Puducherry.
Identification by Customer	: Sample - 1	Sampling Procedure	--
Sample Condition	: Fit for analysis	Sample Received on	28.12.2023
Test Started on	: 28.12.2023	Test Completed on	30.12.2023

Test Parameter	Test Method	Units	Results	Drinking water standard requirements as per IS 10500-2012
BACTERIOLOGICAL ANALYSIS				
Total Coliforms	WHO Guideliness for drinking water Quality - Vp03	MPN/100 ml	Absent	Absent
Faecal Coliforms	WHO Guideliness for drinking water Quality - Vp03	MPN/100 ml	Absent	Absent

Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


Authorized Signatory
L. Anita Ben
BIOCHEMIST
WATER TESTING LAB
PUBLIC HEALTH DIVISION
P.W.D. PONDICHERRY

Copy to:

The Executive Engineer,
P.H.D., P.W.D., Puducherry.

Terms and Conditions

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHD/PWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

